

# Voltage Control in a Novel Three-Phase Line Interactive UPS System with Parallel-Series Active Power Line Conditioning Capabilities using AC Line Reactor

Jun-Keun Ji<sup>1\*</sup>

## AC 라인 리액터와 병렬 및 직렬 능동필터를 가지는 새로운 3상 Line-Interactive UPS 시스템의 전압제어

지준근<sup>1\*</sup>

**Abstract** In this paper a novel 3-phase line interactive UPS(Uninterruptible Power Supply) system with parallel-series active power-line conditioning capability using AC line reactor and two four-leg PWM VSCs(Voltage Source Converters) is proposed. And the strategy of voltage control in proposed UPS system is explained. The objective of voltage control in parallel(shunt) and series PWM VSC of proposed UPS system is to guarantee satisfactory characteristics in steady state and transient state.

**Key words** : Voltage Control, Three-Phase Line Interactive UPS System, Parallel-Series Active Power Line Conditioning Capabilities, AC Line Reactor

**요약** 본 논문은 AC 라인 리액터와 2개의 4레그 PWM 전압형 컨버터를 사용하여 병렬 및 직렬 능동필터 기능을 가지는 새로운 3상 Line-Interactive UPS 시스템을 제안하고 전압제어 방식을 설명한다. 제안하는 UPS 시스템의 병렬 및 직렬 PWM 전압형 컨버터에서 전압제어의 목적은 정상상태 및 과도상태에서 만족스러운 동작 특성을 보장하는 것이다.

### 1. Introduction

The line interactive UPS systems have been widely used to improve the power source quality as well as to maintain the desired load voltage waveform for critical loads such as computers, medical equipment, and industrial control systems, despite of the various power line faults and the voltage deviation condition.[1] Generally there are only a few situations where the UPS system feeds the three-phase balanced load. Most of the loads are single-phase nonlinear and

three-phase unbalanced loads such as single-phase rectifier loads for the switched mode power supply, three-phase rectifiers with dc-side LC filters, etc. Therefore, a zero sequence voltage should be controllable in the three-phase UPS system. However in much research, the controllability of the zero sequence voltage has been ignored.[2-4] For the controllability of the zero sequence voltage, the half-bridge converter topology, with the output nodes of the three legs connected to the center point of DC link, has been used widely for many industry applications.[5] However in the case of the half-bridge topology, the UPS system requires the DC link voltage to be maintained to be at least twice as large as the peak value of the nominal output voltage. The battery voltage should ascend along with the DC link voltage, which brings about the increase of the

---

This work was supported by the 2004 Soonchunhyang University Research Fund (20040060)

<sup>1</sup>Division of information Technology Engineering,  
Soonchunhyang University

\*Corresponding author : Jun-Keun Ji(kji@sch.ac.kr)

material and maintenance cost, since the number of the batteries increases.

The UPS system using the 4-leg voltage source converter proposed in this paper can use the DC link voltage effectively by the carrier-based 3-D SVPWM method<sup>[6,7]</sup> and also has the controllability of the zero sequence voltage as well as the instantaneous symmetrical component voltages. The DC battery voltage can be reduced by 15% in comparison with that of the conventional half-bridge converter type UPS system. This paper describes the novel UPS system with two 4-leg VSCs and AC line reactor, and its voltage control strategy is described. The simulations and experiments have been performed for the verification of the feasibility of the proposed UPS system.

## 2. The proposed UPS system<sup>[8]</sup>

Fig. 1 shows the configuration of the proposed line interactive UPS system. As shown in Fig. 1, the two 4-leg voltage source converters are employed for power line conditioning. One is in parallel with the AC reactor of the power source side and the other is in series with the load. The 4-leg inverters, parallel with the ac reactor and series with the load, will be referred to as a shunt inverter and a series inverter,

respectively. Note that the ac line reactor exists between the power source and the shunt inverter. The shunt inverter acts as a voltage source so as to control the reactor current indirectly. The series inverter acts as a direct voltage restorer so as to eliminate the harmonics and the unbalanced component of the output voltage.

By understanding the carrier-based 3-D SVPWM method, the 4-leg VSC can be completely modified into three single-phase full-bridge converters with an available voltage limited by 0.933Vdc.<sup>[6]</sup> That is to say, the 4-leg voltage source converter is equivalent to three-independently-controllable voltage sources. Hence the proposed system can be simplified by the single phase equivalent circuit as shown in Fig. 2.




Fig. 2 Single phase equivalent circuit of Fig. 1




Fig. 1 Configuration of proposed UPS system

### 3. Voltage Control Strategy

The output voltage reference of the shunt inverter ( $V_{pcap}^*$ ) can be written as eq. (1) using the desired line reactor current ( $I_{src}^*$ ), which is also the desired source current written as eq. (2). The source current is determined by the compensation current reference ( $I_{comp}^*$ ) which is given by the pqr instantaneous power theory<sup>[9]</sup>, so that the sinusoidal source currents are maintained, and the neutral line current is eliminated even when the zero sequence component exists in the source and load side.

$$V_{pcap}^* = V_{src} - sL_{line} I_{src}^* \quad (1)$$

$$I_{src}^* = I_{load} - I_{comp}^* \quad (2)$$

The shunt inverter controls the three-phase line voltage so as to control the line reactor current indirectly. The series 4-leg voltage source inverter compensates the load voltage to be balanced and harmonic-free. Both of the series and parallel 4-leg voltage source inverters always act as independently controllable voltage sources, so that three-phase output voltage shows a seamless transition to the back-up mode with the battery. The conceptual view of the control strategy for the UPS system is shown in Fig. 3. The phase diagram of the controlled voltages ( $V_{pcap}$

and  $V_{scap}$ ) during the normal operation is shown in Fig. 4. If the resistance of ac line reactor ( $R_{line}$ ) is neglected,  $V_{line}$  will be orthogonal to the source current. Therefore the output voltage of the shunt inverter controlled by  $V_{pcap}^*$ , shown in Fig. 4, makes the power source keep the unity power factor.




Fig. 4 UPS operation for unity power factor during the normal operation

### 4. Simulation Results

The simulation has been performed to verify the feasibility of the control strategy for the proposed UPS system. Considering a grid voltage variation of  $\pm 10\%$  fundamental component with 5% third, fifth, and seventh harmonics voltage contents, the proposed UPS system provides a linear unbalanced and nonlinear combined load. The major parameters of the UPS system used in the simulation are summarized in Table I.





Fig. 3 Block diagram of control system

**Table 1.** Suggested UPS system parameters


Grid Rated Power		60kVA/380V	
Lline		0.1pu	
Rline		0.005pu	
Vbattery/Vdc		650V/700V	
Turns Ratio of Series Transformer		1:5	
LC Filters			
Shunt(Parallel)		Series	
Lfp	Cfp	Lfs	Cfs
300uH	200uF	600uH	60uF

Fig. 5 represents the simulation results under the condition that the UPS system feeds the unbalanced

and nonlinear combined loads, and that the A-phase 10% sag occurs at 0.55 sec during 3 cycles. The load currents have zero sequence due to the unbalanced load, and the zero sequence voltage appears in the source voltage during the voltage sag period. The sinusoidal source currents and neutral current elimination are achieved even though both zero sequence voltage and current exist, as shown in Fig. 5(a). Fig. 5(b) shows that proposed UPS system operates at unity power factor. Through these simulation results, the feasibility of the proposed control strategy can be verified.



(a) Sinusoidal source current and elimination of zero sequence current



(b) The voltage and current waveform during the normal operation

**Fig. 5** Simulation Results : Overall performance of the proposed line-interactive UPS system

## 5. Experimental Results

Fig. 6 shows the experimental voltage and current response of normal mode in suggested 60KVA UPS system. Though load current  $I_{load}$  is not in phase with source voltage  $V_{src}$  in case of nonlinear load condition, source current  $I_{src}$  is in phase with source voltage  $V_{src}$ . Also through voltage waveforms of parallel and series PWM converters, it is proved that voltage control of suggested UPS system is successful.




Fig 6. Normal mode response of suggested UPS system

## 6. Conclusions

This paper has proposed a novel topology and its voltage control strategy for three-phase line-interactive UPS system with parallel-series active power-line conditioning capability using two 4-leg voltage source

converters and AC line reactor. The shunt inverter eliminates the neutral line current and the active ripple power of the source side using the pqr transformation so that unity power factor and the sinusoidal source current can be achieved even though both source and load voltages have zero sequence components. The series inverter operating as dynamic voltage restorer(DVR) compensates the line voltage and allows the load voltage to be balanced and harmonic-free. Both of series and shunt inverters always act as independently controllable voltage sources, so that the three-phase output voltage can show a seamless transition to the backup mode in contrast to conventional parallel-series line interactive UPS system needing transition from current source to voltage source at backup mode.

## Reference

- [1] W. Solter, "A New International UPS Classification by IEC 62040-3," INTELEC, pp. 541~545, 2002.
- [2] Youichi Ito and Shoichi Kawauchi, "Microprocessor-Based Robust Digital Control for UPS with Three-Phase PWM Inverter," IEEE Trans. Power Elec. vol. 10, pp. 196~204, Mar. 1995.
- [3] U. Borup, P. N. Enjeti, and F. Blaabjerg, "A New Space-Vector-Based Control Method for UPS Systems Powering Nonlinear and Unbalanced Loads," IEEE Trans. Ind. App. vol. 37, pp. 1864~1870, Nov/Dec 2001.
- [4] F. Kamran and T. G. Habetler, "A Novel On-Line UPS with Universal Filtering Capabilities," IEEE Trans. Power Elec. vol. 13, pp. 410~418, May 1998.
- [5] S. A. O. da Silva, Pedro, P. F. Donoso-Garcia, P. C. Cortizo, and P. F. Seixas, "A three-phase Line-Interactive UPS system Implementation with Series-Parallel Active Power-Line Conditioning Capabilities," IEEE Trans. Ind. App. vol. 38, pp. 1581~1590, Nov/Dec 2002.
- [6] Jang-Hwan Kim and Seung-Ki Sul, "A Carrier-based PWM Method for Three-Phase Four-Leg Voltage Source Converters," IEEE Trans. Power Elec. vol. 19, pp. 66~75, Jan. 2004.

- [7] Jang-Hwan Kim and Seung-Ki Sul, "Overmodulation Strategy for a Three-Phase Four-Leg Voltage Source Converters," Conference Record of IAS'03, pp. 656~662, Oct. 2003.
- [8] Jun-Keun Ji, Jang-Hwan Kim, Seung-Ki Sul, Hyo-Sung Kim, A Novel Three-Phase Line-Interactive UPS System with Parallel-Series Active Power-Line Conditioning Capabilities Using AC Line Reactor," Conference Record of the IEEE Industrial Electronics Society(IECON'04), FB2-6, Nov. 2004.
- [9] Hyosung Kim, F. Blaabjerg, B. Bak-Jensen, and Jaeho Choi, "Instantaneous Power Compensation in Three-Phase Systems by Using p-q-r Theory," IEEE Trans. Power Elec. vol. 17, pp. 701~710, Sep. 2002.

---

**Jun-Keun Ji**

[Regular Member]



- Feb. 1986 : Electrical Engineering (B. S.), Seoul National University
- Feb. 1988 : Electrical Engineering (M. S.), Seoul National University
- Feb. 1994 : Electrical Engineering (Ph. D.), Seoul National University
- Sep. 1994 ~ the present : Div. of Information Technology Engineering, Soonchunhyang University, Professor

<Areas studied> : Power Electronics, Electric Machine, Motor Control, Power Supply, Power Quality Control, Motion Control, Control Application